



CERTIFICATE OF FLAME RESISTANCE

Certificate Holder: Arisia, Inc.
131 Daniel Webster Highway 101
Nashua, NH 03060

For: Arisia, Inc.

Certificate Date: January 9, 2014

Certificate Number: 12199

Expiration Date: January 8, 2015

National Assembly Original

This is to certify that the following items have been treated with a flame retardant and are flame resistant in accordance with the ICC International Fire Code Chapter 8 and NFPA 1: Fire Code 20.1.2. The items were sprayed with a flame retardant chemical registered with the California Fire Marshall and the NYC Fire Department. These materials have been tested and meet the guidelines of NFPA 701 and are suitable for use in areas of Assembly Occupancy.

- Items:** 8 Drapes, 4'-6"w x 9'-8"h, black, cotton
- 10 Drapes, 4'-6"w x 7'-9"h, black, cotton
- 1 Drapes, 7'-4"w x 6'-10"h, black, cotton


--end of certificate--

Registry No.: FDNY Cert. of Approval #5022
CSFM Registration #C-06302

The warranted period of effectiveness is One Year and may be renewed by appropriate Testing in accordance with International Fire Code 803.4 and NFPA 1: C.9-2.5.3. Any washing, cleaning or alteration of this material will void this certificate.



Sworn to before me this day
January 9, 2014


ELLEN B SILVERMAN
ID.# 2430204
NOTARY PUBLIC
STATE OF NEW JERSEY
My Commission Expires Feb. 20, 2018

Signed and attested to:


Tom Andrews
NYC FD Certificate #62200068
NFPA Member #1103770